

# CONCRETE SUBSTRATE READINESS CHECKSHEET

## for Deck Installation

### Gripset 38/Gripset 2P Membranes



<b>Project/Site Name</b>	
<b>Site Address</b>	
<b>Applicator</b>	
<b>Main Contractor</b>	

QC process	✓	Tick when completed
Smooth clean surface. Repair any soft or poor condition screed concrete substrate.	<input type="checkbox"/>	
Cavities and cracks to be filled with Gripset DM mortar and flushed off.	<input type="checkbox"/>	
Old existing concrete may need to be cup ground, clear of surface contamination. Check with the installing applicator.	<input type="checkbox"/>	
Surface smooth and clean to specified falls, otherwise to NZBC.	<input type="checkbox"/>	
No fillets to all internal corners.	<input type="checkbox"/>	
Check moisture content if too high. Gripset P10 Vapour Block may be required.	<input type="checkbox"/>	
Radius all external corners.	<input type="checkbox"/>	
If terminating into a chase, pre-form the chase and ensure that it is straight and 20mm deep.	<input type="checkbox"/>	
Allproof SUREFLOW ring clamp dropper outlets and overflows are installed recessed just under flush with the substrate surface.	<input type="checkbox"/>	
Allproof overflow sumps are installed recessed just under flush with the substrate surface.	<input type="checkbox"/>	
Type 316 Stainless Steel or Aluminium scupper outlets are installed recessed just under flush with the substrate surface, and primed with Gripset OP Primer.	<input type="checkbox"/>	
Plinths formed for any exterior ventilation, fixtures or similar.	<input type="checkbox"/>	
Deck threshold heights to be 100mm minimum (refer to NZBC).	<input type="checkbox"/>	

**WHEN THE SUBSTRATE IS READY, COMPLETE THIS FORM AND EMAIL TO THE WATERPROOFING SUBCONTRACTOR**

<b>Notes</b>			
<b>Name</b>			
<b>Signature</b>		<b>Date</b>	