

# SUBSTRATE READINESS CHECKSHEET

## for Bathroom & Laundry Installation

### Gripset 38/Gripset 2P Membranes



<b>Project/Site Name</b>	
<b>Site Address</b>	
<b>Applicator</b>	
<b>Main Contractor</b>	

QC process	✓	Tick when completed
<b>FLOORS</b>		
Plywood floors must be overlaid with Hardies tile-to-timber boards to Hardies installation specification.	<input type="checkbox"/>	
Concrete or screed substrate is cured and thoroughly dry, maximum moisture content 20%.	<input type="checkbox"/>	
Surface smooth and clean with specified falls.	<input type="checkbox"/>	
Cavities and cracks filled with Gripset DM and flushed off to give a smooth surface.	<input type="checkbox"/>	
Concrete or screed substrate is solid free from latescence. Dust and loose particles must be removed.	<input type="checkbox"/>	
No mortar fillets, a 90 degree square edge finish is required.	<input type="checkbox"/>	
Allproof tile outlet fitting is installed to correct height with protective cover.	<input type="checkbox"/>	
Surface smooth and clean to specified falls, otherwise to NZBC.	<input type="checkbox"/>	
<b>WALLS</b>		
Gib board or Villa boards installed correctly.	<input type="checkbox"/>	
Gib board or Villa board stopped flush to supplier's specification.	<input type="checkbox"/>	
The gap between the floor substrate and bottom of sheet edge is filled with WPS MS40 sealant tooled off flush to form a 90 degree CRN.	<input type="checkbox"/>	

**WHEN THE SUBSTRATE IS READY, COMPLETE THIS FORM AND EMAIL TO THE WATERPROOFING SUBCONTRACTOR.**

<b>Notes</b>			
<b>Name</b>			
<b>Signature</b>		<b>Date</b>	